Notes

Area to be resurfaced - 1071m²

Plane off 65mm of existing construction and replace with the following:-

Surface course
20mm layer of 3mm size fine graded wearing course to BS4987:Part 1 (7.7) with 200, 300 or 450 pen bitumen.

or

20mm layer of 6mm size dense wearing course to BS4987:Part 1 (7.5) with 100 or 200 pen bitumen.

The aggregate shall be hardstone crushed rock course aggregate with a minimum PSV of 55.

Binder course
45mm layer of 20mm size dense basecourse to BS4987:Part 1 (6.5) with 150 pen or 200 pen bitumen

	Date	Revision

Fylde Council

Technical Services
Development Services
The Town Hall
Lytham St Annes
Lancashire
FY8 1LW

Tel: 01253 658658 E-mail: webmaster@fylde.gov.uk

Drawn By:	Date:
MJB	April 2016
Checked By:	Scale:
SB	1:500

Project:

Hope Street Park Resurfacing

Title:

Plan - Option 1

Drawing Number:

TS16007/01