

Hi Mick,

With regards to the removal of the accessible telephone for contacting the emergency services, Lancashire Fire and rescue service would expect a review of the fire risk assessment to take place and any significant findings following this review are actioned accordingly and as soon as practicable.

Where reliance on the mobile phone network is required, a survey of the signal strength should be considered and conducted by the 'responsible person'.

Regards



Watch Manager  
Alan Priestley  
Fire Safety Inspector  
W36 St Annes  
Lancashire Fire and Rescue Service  
01253-716726  
Mobile 07920786805  
Internal 2-3631/2  
[alanpriestley@lancsfireandrescue.org.uk](mailto:alanpriestley@lancsfireandrescue.org.uk)

**From:** Michael Duck [<mailto:michael.duck@fylde.gov.uk>]  
**Sent:** 29 January 2018 12:59  
**To:** W36 - Priestley, Alan  
**Subject:** Caravan Site Licensing

Hi Alan,

I can confirm that I have received an application from the site owner to remove condition 17 from the site licence, in respect of an available phone for calling the emergency services on the site.

In accordance with the Caravan Sites and Control of Development Act 1960, would it be possible to have your views on this matter.

Many thanks

Micky

**Michael Duck**  
**Senior EHO - Commercial Team**

**Extension: 8620**